

**U.S. EPA REGION 8
HEARING CLERK**

)

)

)

)

)

)

;

)

1. This Order is issued under the authority vested in the Administrator of the United States Environmental Protection Agency (EPA) by section 1414(g) of the Safe Drinking Water Act (Act), 42 U.S.C. § 300g-3(g), as properly delegated to the undersigned official.
2. Manjot Pandher (Respondent) is an individual that owns the Akal Energy-Buford Outpost Public Water System (System), which provides piped water to the public in Albany County, Wyoming, for human consumption.
3. The System is supplied by a groundwater source accessed via one well. The water is treated by conventional filtration system.
4. The System has approximately one service connection and regularly serves an average of approximately 44 individuals daily at least 60 calendar days out of the year. Therefore, the System is a “public water system” as defined in section 1401(4) of the Act, 42 U.S.C. § 300f(4), and 40 C.F.R. § 141.2. Further, the System is a non-community water system that does not regularly serve at least 25 of the same persons over six months per year and, as such, is also a “transient non-community water system” as defined in 40 C.F.R. § 141.2.
5. Respondent is a “person” as defined in section 1401(12) of the Act, 42 U.S.C. § 300f(12) and are subject to the Act and 40 C.F.R. part 141 (Part 141). Part 141 is an “applicable requirement” as defined in section 1414(i) of the Act, 42 U.S.C. § 300g-3(i).
6. Part 141 includes monitoring requirements. The EPA has sent annual notifications of the applicable monitoring requirements to the System.

VIOLATIONS

7. If the System (1) has more than one positive total coliform sample result within the same month or (2) fails to take three total coliform repeat samples within 24 hours following a routine total coliform positive result, Respondent is required to conduct a Level 1 assessment and submit it to the EPA within 30 calendar days of learning of the monitoring results. 40 C.F.R. § 141.859. In September 2023, the System had multiple positive total coliform sample results, and Respondent failed to conduct a Level 1 assessment and submit it to the EPA within 30 days. In August 2025, Respondent failed to take three total coliform repeat samples within 24 hours following a routine total coliform positive result, and Respondent again failed to conduct a Level 1 assessment and submit it to the EPA within 30 days. Respondent therefore violated this requirement.
8. If the System does not treat its water to meet at least a 4-log, 99.9% removal of viruses, Respondent is required to conduct triggered source monitoring within 24 hours of being notified that a regular, routine total coliform monitoring sample is positive for total coliform. Respondent must sample each groundwater source and have it analyzed for a fecal indicator (e.g., *E. coli*). 40 C.F.R. § 141.402. Respondent failed to monitor the System's source for a fecal indicator within 24 hours after being notified on September 29, 2023, that a sample taken on September 28, 2023, was analyzed as total coliform positive. Respondent again failed to monitor the System's source for a fecal indicator within 24 hours after being notified on August 5, 2025, that a sample taken on July 17, 2025, was analyzed as total coliform positive. Respondent therefore violated this requirement.
9. Respondent is required to monitor the System's water monthly for total coliform bacteria. 40 C.F.R. §§ 141.853-858. Respondent failed to monitor the System's water for total coliform bacteria during September 2024 and therefore violated this requirement. (Note: The System subsequently monitored for total coliform bacteria in October 2024.)
10. Respondent is required to monitor the System's water annually for nitrate at every entry point to the distribution System which is representative of each well after treatment. 40 C.F.R. §§ 141.23(a) and (d). Respondent failed to monitor the

System's water for nitrate during 2023 and therefore violated this requirement.

(Note: The System subsequently monitored for nitrate in February 2024.)

11. Respondent is required to report monitoring results for nitrate and nitrite to the EPA within the first 10 calendar days following the end of the month in which the results were received or, if sooner, the first 10 calendar days after the end of the monitoring period. 40 C.F.R. § 141.31. Respondent failed to report nitrate and nitrite monitoring results for samples collected on May 22, 2022, by this deadline and therefore violated this requirement. (Note: The System subsequently reported nitrate and nitrite monitoring results on May 23, 2022.)
12. Respondent is required to notify the public of certain violations of Part 141 and, within 10 calendar days after completing public notice, provide a copy of the public notice and certification to the EPA. 40 C.F.R. §§ 141.31(d) and 141.201-141.211. The violation identified in paragraph 7 above, is classified as a violation requiring Tier 2 public notice within 30 calendar days, with the public notice to be repeated every three months and for notice to remain in place for as long as the violation or situation persists, according to 40 C.F.R. § 141.203. The EPA's records reflect that the Respondent failed to notify the public of the violation cited in paragraph 7 and failed to submit a copy of the public notice and certification to the EPA and therefore violated this requirement.
13. Respondent is required to notify the public of certain violations of Part 141 and, within 10 calendar days after completing public notice, provide a copy of the public notice and certification to the EPA. 40 C.F.R. §§ 141.31(d) and 141.201-141.211. The violations identified in paragraphs 8, 9, and 10, above, are classified as violations requiring Tier 3 public notice within 1 year, according to 40 C.F.R. § 141.204. The EPA's records reflect that the Respondent failed to notify the public of the violations cited in paragraphs 8, 9, and 10, and 11 and failed to submit a copy of the public notice and certification to the EPA and therefore violated this requirement.
14. Respondent is required to report any failure to comply with Part 141 to the EPA within 48 hours (except where Part 141 specifies a different time period). 40 C.F.R. § 141.31(b). Respondent failed to report the violations cited in paragraphs 7, 8, and 10, above, to the EPA and therefore violated this requirement.

15. Respondent is required to report any violation of total coliform monitoring requirements to the EPA within 10 calendar days after discovering the violation. 40 C.F.R. § 141.861(a)(4). Respondent failed to report the violation listed in paragraph 9, above, to the EPA and therefore violated this requirement.

ORDER

Respondent is ordered to perform the following actions upon Respondent's receipt of this Order (unless a different deadline is specified below):

16. Respondent is ordered to comply with all provisions of the Act and Part 141, including but not limited to each requirement cited above.
17. Within 15 calendar days of receipt of this Order, Respondent shall conduct a Level 1 assessment and submit the attached Revised Total Coliform Rule Level 1 assessment form to the EPA. The assessment shall determine the causes of the 2023 and 2025 total coliform-positive samples, identify corrective actions for all sanitary defects, and include a proposed schedule (Schedule) and plan for completion of all corrective actions after consulting with the EPA. The Schedule shall be incorporated into this Order with each milestone to be an enforceable requirement upon written approval by the EPA. Within 10 calendar days after completing all tasks included in the Schedule, Respondent shall notify the EPA of the project's completion. Respondent shall provide sufficient evidence to the EPA, including photographs of the corrective actions. 40 C.F.R. § 141.859.
18. Within 48 hours after receipt of this Order, Respondent shall collect at least one water sample from its groundwater source and have it analyzed for a fecal indicator (e.g., *E. coli*). If a sample is *E. coli* positive, Respondent shall notify the EPA immediately for appropriate assistance 40 C.F.R. § 141.403(a)(4). Respondent shall comply with the treatment technique requirements, according to 40 C.F.R. § 141.403(a), and provide appropriate public notification pursuant to 40 C.F.R. § 141.402(g) within 24 hours as required by 40 C.F.R. § 141.202(b)(1). Thereafter, Respondent shall comply with all source water monitoring and related requirements in 40 C.F.R. § 141.402. When reporting any triggered source water sample result, Respondent shall specify that it is a triggered source water sample.

19. Respondent shall monitor the System's water monthly for total coliform bacteria. If a sample is positive for total coliform, within 24 hours of being notified of the positive result, Respondent shall collect a set of three repeat samples for each total coliform-positive sample from the sample sites identified on the RTCR sample siting plan. 40 C.F.R. § 141.853-858. Respondent shall report results to the EPA within the first 10 calendar days following the end of the required monitoring period. 40 C.F.R. § 141.31(a).
20. Respondent shall monitor the System's water annually for nitrate, in accordance with 40 C.F.R. §§ 141.23(a) and (d). Respondent shall report results to the EPA within the first 10 calendar days following the end of the required monitoring period. 40 C.F.R. § 141.31(a).
21. For any future violation of Part 141 for which this Order does not specify a reporting period, Respondent must report the violation to the EPA within 48 hours of the violation occurring, as required by 40 C.F.R. § 141.31(b). However, if Part 141 specifies a different time period for reporting the particular violation, Respondent must report the violation to the EPA within that different period.
22. Within 30 calendar days after receipt of this Order, and quarterly thereafter as long as the violation cited in paragraph 7, above, persists, Respondent shall notify the public of this violation. Thereafter, following any future violation of Part 141, Respondent shall comply with any applicable public notice provisions of 40 C.F.R. part 141, subpart Q. Within 10 calendar days after providing public notice, Respondent shall submit a copy of the notice and certification to the EPA. 40 C.F.R. § 141.31(d). Templates and instructions are available at:
<https://www.epa.gov/region8-waterops/reporting-forms-drinking-water-systems-wyoming-and-tribal-lands-epa-region-8#pn>.
23. Within 30 calendar days after receipt of this Order, Respondent shall notify the public of the violations cited in paragraphs 8, 9, 10, and 11, above. Thereafter, following any future violation of Part 141, Respondent shall comply with any applicable public notice provisions of 40 C.F.R. part 141, subpart Q. Within 10 calendar days after providing public notice, Respondent shall submit a copy of the notice and certification to the EPA. 40 C.F.R. § 141.31(d). Templates and

instructions are available at: <https://www.epa.gov/region8-waterops/reporting-forms-drinking-water-systems-wyoming-and-tribal-lands-epa-region-8#pn>.

24. If the population or number of connections served by the System at least 60 days of the year falls below 25 individuals, Respondent must notify the EPA in writing within 10 calendar days by submitting a completed basic information form. The form is available at: <https://www.epa.gov/region8-waterops/reporting-forms-drinking-water-systems-wyoming-and-tribal-lands-epa-region-8#new>.
25. If Respondent (a) leases or sells the System to another person or entity, or (b) contracts with or hires any other person or entity to operate the System, Respondent must, within 10 calendar days, provide a copy of this Order to the lessee, purchaser, or contractor and notify the EPA in writing of the change. In either of these circumstances, Respondent will remain obligated to comply with this Order.
26. Respondent must send all reporting and notifications required by this Order to the EPA at: Email: R8DWU@epa.gov, and Bell.marlon@epa.gov

GENERAL PROVISIONS

27. This Order is binding on Respondent, and any person (*e.g.*, employee, contractor, or other agent) acting in concert with Respondent.
28. This Order does not constitute a waiver, suspension, or modification of any requirement of the Act or Part 141. Issuance of this Order is not an election by the EPA to forgo any civil or criminal action.
29. Violation of any part of this Order, the Act, or Part 141 may subject Respondent to a civil penalty of up to \$71,545 (as adjusted for inflation) per day of violation, a court injunction ordering compliance, or both. 42 U.S.C. § 300g-3; 40 C.F.R. part 19; 90 Fed. Reg. at 1375 (January 8, 2025).

30. Respondent may seek federal judicial review of this Order pursuant to section 1448(a) of the Act, 42 U.S.C. § 300j-7(a).

Issued: October 1, 2025.

Colleen Rathbone, Manager
Water Enforcement Branch
Enforcement and Compliance Assurance Division